



STATE OF TENNESSEE
ENVIRONMENT AND CONSERVATION

**INVITATION TO BID # 32701-13255
AMENDMENT # 1
FOR FALL CREEK FALLS CAMPGROUND DUMP
STATIONS**

DATE: March 27, 2024

ITB # 32701-13255 IS AMENDED AS FOLLOWS:

1. This ITB Schedule of Events updates and confirms scheduled ITB dates. Any event, time, or date containing revised or new text is highlighted.

Event	Time	Due Date
Event Posted	8:00 am CT	3-8-2024
Questions and Comments Due	4:30 pm CT	3-21-2024
Bids Due	2:00 pm CT	4-01-2024

2. State responses to questions and comments in the table below amend and clarify this ITB.

Any restatement of ITB text in the Question/Comment column shall NOT be construed as a change in the actual wording of the ITB document.

ITB SECTION	PAGE #	QUESTION / COMMENT	STATE RESPONSE
		1. General Conditions #2 references permits. Please provide a list of required permits and associated cost.	Facilities Management is not requiring a permit. As stated, if you permit this work, it shall be the responsibility of the contractor as well as associated cost.
		2. Please provide all available as built documents for the existing dump station area.	There are no existing as built for the existing.
		3. Please provide a map to location that removed topsoil shall be stored.	As stated at the bid meeting the park manager or an appointed individual will escort the contractor to the approved disposal site.
		4. Scope of New Work #3 refers to three new dump stations. #6 refers to six each dump points. Event Details indicates two dump stations – please clarify.	Scope states 3 new islands with 2 dump stations each island and a traffic lane on each side of the island.
		5. Scope of New Work #1 refers to removing existing dump station. Please clarify extent and limits of this work.	After completion of new dump stations contractor shall excavate waste line and cap at a point near sewer main. Then remove all concrete add gravel and prepare for paving.
		6. Please provide a drawing or marked photograph indicating:	N/A

ITB SECTION	PAGE #	QUESTION / COMMENT	STATE RESPONSE
		a.All limits of the work described in Demolition item #3. b. All layout, limits, dimensions, and locations of piping in Scope of New Work items #2 through #10. c. Final grading and drainage plan.	
		7. Please provide location for all asphalt, concrete, topsoil, and other debris to be placed	The park manager will escort the winning bidder to disposal site. Disposal site shall be on park property in proximity.
		8. Please indicate in a drawing or map the location of the force water main located near the work area.	N/A
		9. At pre bid trees were not yet removed. Confirm that the contractor will not have to remove any trees and will only need to grind the specified stumps outlined in the specs.	Trees shall be removed as stated the contractor shall be responsible for stump removal.
		10. Indicate on a map or drawing the location and tie in point for water to the hydrants on the islands.	N/A
		11. Indicate the color and design of signage in the specs	Brown in color, white lettering with white border around sign.
		12. Provide a drawing showing the limits of pavement	N/A

3. **ITB Amendment Effective Date.** The revisions set forth herein shall be effective upon release. All other terms and conditions of this ITB not expressly amended herein shall remain in full force and effect.