



STATE OF TENNESSEE
Department of Correction

**INVITATION TO BIDS # 32947-13285
AMENDMENT # 1
FOR MCCX Generator Maintenance**

DATE: 04/24/24

ITB # 32947-13285 IS AMENDED AS FOLLOWS:

1. State responses to questions and comments in the table below amend and clarify this ITB.

Any restatement of ITB text in the Question/Comment column shall NOT be construed as a change in the actual wording of the ITB document.

ITB SECTION	PAGE #	QUESTION / COMMENT	STATE RESPONSE
		<p>1. last week during our meeting I could not locate the engine serial number or model numbers ID plate, Someone in the group said they had that information and would make it accessible to us all.</p>	<p>Equipment Model: 2800REOZD Equipment Serial No: 2135424 Engine Model:MTU 20V4000 Engine Serial No:528100486 Spec# / Arrange# / CPL#GM29817-GA2</p> <p>Equipment Model: 2800REOZD Equipment Serial No: 2135423 Engine Model:MTU 20V4000 Engine Serial No:528100510 Spec# / Arrange# / CPL#GM29817-GA2</p>
		<p>2. Also do you have a format you require us to use when sending the bid or do we submit it on our quote format?</p>	<p>Please provide your bid inside Edison or print out the Edison generated solicitation and provide your answers within that format. Bids submitted outside the prescribed format may be non-responsive.</p>
		<p>3. Also, if I'm not mistaken, The State mentioned this would be a two year agreement with the option to renew for the third and fourth year? On the Specifications Generator Maintenance Page six speaks of a three year service, just need to clarify.</p>	<p>This will be a three (3) year contract, with two options to renew after the initial 3 year term. Please see the updated Terms and Conditions Document.</p>
		<p>4. What will be the length requirements on the load test and where will this be connected at,</p>	<p>4 hours</p>

ITB SECTION	PAGE #	QUESTION / COMMENT	STATE RESPONSE
		the genset or some other location such as the switchgear?	
		5. On the three year page it talks about rebuilding the fan hub etc.. Will this need to be a part of this bid, if I understood correctly? This will be a two year bid with the option for the third and fourth?	This will be a three (3) year contract, with two options to renew after the initial 3 year term. All items within the specs must be completed during that time and included as part of your bid on the line items in Edison.
		6. I think I heard Marty mention about an emergency rental bid, will this need to be part of the two year bid. With the larger 2800's an expensive transformer will be needed.	Please see response to question 3
		7. Do we have a date yet assigned when all bids must be returned for consideration?	Please refer to the Edison solicitation. Currently bids are due by 2pm CT on 05/06/24, but this may change depending on a number of circumstances.
		8. Is there a hv breaker located at/on the 2.8mw units? 2800 kw units	yes

2. **Delete ITB document 13285_Terms_and_Conditions in its entirety and replace it with 13285_Terms_and_Conditions_Updated (any sentence or paragraph containing revised or new text is highlighted):**

3. **Delete ITB document MCCX_Generator_Specs in its entirety and replace it with MCCX_Generator_Specs_Updated (any sentence or paragraph containing revised or new text is highlighted):**

4. **ITB Amendment Effective Date.** The revisions set forth herein shall be effective upon release. All other terms and conditions of this ITB not expressly amended herein shall remain in full force and effect.